

## ADDENDUM NO. 2

### Florida City American Rescue Plan Act - WATER SYSTEM IMPROVEMENTS: NW 6 AVE AND WTP ENGINEER'S PROJECT NUMBER: 24-019.02

December 13, 2024

---

1. Note that Sheet 5 Water Line Abandonment Plan was added to the plans. Check the revised plans.
2. In the revised Plan Sheet 3 "NW 6 Ave – Water Improvements plan and profile" please note the following has been added:
  - The proposed additional 1" water service and water meter for the existing building.
  - The abandonment of the water service for the existing building.
  - The existing fire hydrant information.
  - The proposed interconnection between the existing 6" water line on NW 6 Ave and the proposed 12" water main at station 0 + 29.3 (14.5' RT). Northeast corner NW 6<sup>th</sup> Ave and NW 4<sup>th</sup> St.
3. In the revised Plan Sheet 4 "WTP – Water Improvements Plan and Profile" please note the following:
  - The additional demolition work.
  - The added Gate Valve callout.
  - The proposed interconnection at station 3 + 92.2 (110' RT) between the existing 16" water line currently delivering the water to the tank and the proposed 16" water main. Profile has also been added.
4. In the revised Plan Sheet 6 "Restoration Plan" the site and pavement areas restoration areas have been updated.
5. In the revised Plan Sheet 7" Standard Details" note the additional details.
6. The Procurement Bid/Proposal Form has been revised with new pay items and quantities.
7. Note that our revised Cost Estimate for the project is: \$ 893,591.40.